

**Oxygen Transfer Tests for
Supratec Plate-Diffuser,
Type OXYFLEX MF1100 “Efficient”
Report**

27 July 2015

Emscher Wassertechnik GmbH
Brunnenstr. 37
45 128 Essen, Germany
Phone: +49(0)201 / 3610 - 0 (Secretariat)
Fax: +49(0)201 / 3610 -100

Determination of the Oxygen Transfer Efficiency and the Pressure Loss for Membrane Plate-Diffusers

1. Purpose of the Tests

In the context of a tendering procedure Emscher Wassertechnik was commissioned with oxygen transfer tests for aerators. The tests were carried out in the experimental station of Emschergenossenschaft at the wastewater treatment plant Emschermündung.

2. Test Set-up

The test tank comprises a steel structure fitted with portholes on one side, which allow the visual evaluation of bubble development and flow conditions. With an area of 6 x 6 m and a water depth of roughly 3.90 m, the tank has a volume of approximately 140 m³. Consequently, the results can be applied to full-scale plants.

The compressed air was generated by means of rotary piston blowers, manufacturer: Spelleken. A blow-off valve made it possible to infinitely variable adjust the quantity of air in each case.

For accurate registration of air volume an adapted measurement instrument is installed in the middle of the downpipe, manufacturer of measurement instrument: Krohne OPTISWIRL 4070 - DN 40. The measurement instrument has a firmware version for density compensation of gases via integrated pressure and temperature sensor. The air volume is recorded using data logger, the average air volume of the evaluation period is used as calculated value of the air volume. A pressure gauge, installed approx. 1 m downstream of the orifice plate, allows determination of the pressure losses in the system. The measured value is also continuously recorded using data logger.

Air was supplied via a stainless steel pipe (DN 100), to which a transverse distribution pipe (DN 100), equipped with seven slide valves (2"), was connected. Three of these valves were connected with tubes (2") to the distribution pipe for the diffusers.

The arrangement of the diffusers in the tank was chosen by the customer respectively by the operating tenderer. 33 plate-diffusers with EPDM-membrane, manufactured by Supratec, Type OXYFLEX MF1100 "Efficient" with a gassing surface of approx. 0.2 m² per plate-diffuser were installed. Relating to the base area of the tank it results from this a rate of coverage of $(33 \times 0.2 \text{ m}^2) / 36 \text{ m}^2 = 18 \%$. The construction height of the diffusers above the tank floor was roughly 13 cm (up to the middle point of the diffusers).

The arrangement of diffusers in the tank is shown in the following image.




Figure 1: Arrangement of diffusers in the test tank

Oxygen measurement devices were placed at 2/3 length of a central bar at different levels. The level of the lowest measurement device was roughly 1.0 m, the level of the middle measurement device was roughly 2.0 m and the level of the upper measurement device was 3.0 m above the tank floor.

3. Testing Method

Diffusers were tested with four different quantities of air. The quantity of air was specified by customer.

The tests were performed in accordance with DIN EN 12255-15¹ and the DWA recommendations M 209². The oxygen transfer tests were carried out in clean (tap) water, with a depth of 3.90 m. The depth of immersion was, thus, 3.77 m.

¹ DIN EN 12255-15: „Messung der Sauerstoffzufuhr in Reinwasser in Belüftungsbecken von Belebungsanlagen“, April 2004

² ATV-DVWK-Merkblatt M 209: „Messung der Sauerstoffzufuhr von Belüftungseinrichtungen in Belebungsanlagen in Reinwasser und in belebtem Schlamm“, GFA, St. Augustin, April 2007

Cobalt (II) sulphate was used as catalyst to deoxygenate the tank contents. This was added in dissolved form prior to the beginning of the test in such quantity that the C_o -concentration was 0.5 mg/l. To ensure uniform distribution, the sodium sulphite was slowly strewn in along both sides of the existing walkway during operation.

The oxygen content was measured by means of three factory-calibrated LDO measurement devices, manufactured by Hach-Lange. The measurement devices use an optical, drift-free method for measurement of dissolved oxygen. The oxygen concentration was continuously measured and recorded with a data logger. The data was then transferred to a computer and analysed. When the increase in the oxygen concentration was less than 0.1 mg/(l*hr) measurements were ended.

The water was replaced, if a critical concentration of salt of 2,000 mg TDS/l (conductivity roughly 3,000 μ S/cm) was reached during a test.

4. Test Evaluation

The evaluation of oxygen uptake with non-linear regression was done with software OCAW, a special software for absorption and desorption measurements. The theoretical final saturation value ($C_{S,md,20}$) at the half depth of entry was the basis for the evaluation purposes. To adjust the influence of salt concentration in the tank the aeration coefficient k_{La20} is corrected with the measured conductivity with the following equation for a salt concentration of 1.000 mg/l:

Aeration coefficient $k_{La20,1000}$ [1/hr] = $k_{La20} * 1.1 / (1 + 0.1 * 2/3 LF / 1000)$.

The listed power input and the calculated gross oxygen yield are based on calculated values, they are used for a comparison of the tested diffusers. The power input was determined in each case based on the air quantity measured, using the equation:

$$N_B = \frac{Q_L * \gamma_w * p}{\eta * 75 * 1.36} \text{ [kW]}$$

The efficiency η was taken as being 0.6 in all cases. As the yield at a waste water treatment plant depends on the whole system (efficiency blowers, installation of pipes, control system, control valves etc.), the results of the pilot plant are not usable in practise directly.

Figure 2 shows the specific oxygen uptake [g/(Nm³*m)] as a function of the quantity of air supplied per diffuser and time.

The pressure loss [hPa] of aeration system including supply pipe as a function of the quantity of air supplied per diffuser and time are shown in figure 3. Additional test series with dry diffusers was carried out in a small separate test tank with installed single diffusers.




Figure 2: Oxygen uptake as a function of the quantity of air supplied




Figure 3: Pressure loss of aeration system including supply pipe and additional test with dry diffusers as a function of the specific quantity of air supplied

5. Summary

At the 28th Mai 2015, tests in clean/tap water were performed in a test tank at the experimental station of the Emschergenossenschaft to determine the oxygen input capacity, oxygen yield and specific oxygen uptake achieved with the EPDM-membrane plate-diffusers manufactured by Supratec, Type OXYFLEX MF1100 "Efficient". The tests, as well as their evaluation, were carried out in accordance with DIN EN 12255-15 and the DWA-Recommendations M 209. Four oxygen input tests were performed in total in a tank with a volume of roughly 140 cubic metres. The air quantities were varied without modifying the configuration, so that the results can be shown as a function of the air quantity.

Evaluation of the test results produced the following values:

Spec. quantity of air		Pressure loss		SSOTR
Per diffuser	Per m ³ tank volume	Incl. supply pipe	Dry diffuser (separate test tank)	
[Nm ³ /(hr*diffuser)]	[Nm ³ /(hr*m ³)]	[hPa]	[hPa]	[g/(Nm ³ *m)]
4.54	1.07	26	21	21.1
5.52	1.30	30	24	20.8
9.01	2.12	42	31	19.1
12.12	2.85	53	37	18.5

Essen, 27 July 2015



i.V. Dipl.-Ing. Peter Wulf



i.A. Dipl.-Ing. Martin Hetschel

Project: waste water treatment plant Gabal el Asfar

Realisation with OXYFLEX® membrane diffuser

Technical data

 design of the diffuser
diffuser type
version
material of the membrane

 water depth
diffuser working depth
α - alpha-factor (supposed)
β- beta-factor (supposed)

Diffuser feed

 max. short-time feed (maintenance purpose)
max. permanent feed
chosen feed
min. feed

Layout

 number of drop pipes
number of distribution pipes per drop pipe
number of diffuser per distribution pipe
recommended quantity of diffusers
Operating Diffuser Airflow: average AOR

 resulted air feed per diffusers
resulted air feed per m² of diffuser surface
specific standard oxygen transfer rate (SSOTR)
specific standard oxygen transfer efficiency (SSOTE)
standard oxygen transfer rate (SOTR/SOR)
standard oxygen transfer rate - in waste water (αSOTR/AOR)
therefor required air amount
Operating Diffuser Airflow : maximal AOR

 resulted air feed per diffusers
resulted air feed per m² of diffuser surface
specific standard oxygen transfer rate (SSOTR)
specific standard oxygen transfer efficiency (SSOTE)
standard oxygen transfer rate (SOTR/SOR)
standard oxygen transfer rate - in waste water (αSOTR/AOR)
therefor required air amount
Operating Diffuser Airflow : total 113.000 Nm³/h

 resulted air feed per diffusers
resulted air feed per m² of diffuser surface
specific standard oxygen transfer rate (SSOTR)
specific standard oxygen transfer efficiency (SSOTE)
standard oxygen transfer rate (SOTR/SOR)
standard oxygen transfer rate - in waste water (αSOTR/AOR)
therefor required air amount
Operating Diffuser Airflow : total 171.000 Nm³/h

 resulted air feed per diffusers
resulted air feed per m² of diffuser surface
specific standard oxygen transfer rate (SSOTR)
specific standard oxygen transfer efficiency (SSOTE)
standard oxygen transfer rate (SOTR/SOR)
standard oxygen transfer rate - in waste water (αSOTR/AOR)
therefor required air amount
tank

 length of tank
width of tank
floor area of the tank
No. of tanks
diffuser coverage density

active area for each diffuser
total active diffuser area

Data under consideration of an arrangement with mixer
Data under consideration of a full extensively arrangement!
pressure loss (considering condition as delivered)

	per tank	total	
	plate	plate	
	OXYFLEX® MF1100	OXYFLEX® MF1100	
	Efficient	Efficient	
	EPDM	EPDM	
	6,25	6,25	m
	6,05	6,05	m
	0,65	0,65	
	1,00	1,00	
	14,0	14,0	Nm ³ /h per diffuser ¹
	12,0	12,0	Nm ³ /h per diffuser ¹
	4,5	4,5	Nm ³ /h per diffuser ¹
	2,0	2,0	Nm ³ /h per diffuser ¹
	15	120	piece
	3	3	piece
	35	35	piece
	1575	12600	piece
	4,5	4,5	Nm ³ /h per diffuser ¹
	22,6	22,6	Nm ³ /h per m ² active diffuser area ¹
	21,5	21,5	g O ₂ /Nm ³ /m installation depth ¹
	7,2	7,2	% per m installation depth
	925	7397	kg O ₂ /h
	601	4808	kg O ₂ /h
	7108	56867	Nm ³ /h
	5,5	5,5	Nm ³ /h per diffuser ¹
	27,7	27,7	Nm ³ /h per m ² active diffuser area ¹
	20,5	20,5	g O ₂ /Nm ³ /m installation depth ¹
	6,8	6,8	% per m installation depth
	1082	8654	kg O ₂ /h
	703	5625	kg O ₂ /h
	8722	69780	Nm ³ /h
	9,0	9,0	Nm ³ /h per diffuser ¹
	44,8	44,8	Nm ³ /h per m ² active diffuser area ¹
	18,2	18,2	g O ₂ /Nm ³ /m installation depth ¹
	6,1	6,1	% per m installation depth
	1555	12442	kg O ₂ /h
	1011	8088	kg O ₂ /h
	14125	113000	Nm ³ /h
	13,6	13,6	Nm ³ /h per diffuser ¹
	67,9	67,9	Nm ³ /h per m ² active diffuser area ¹
	16,0	16,0	g O ₂ /Nm ³ /m installation depth ¹
	5,3	5,3	% per m installation depth
	2069	16553	kg O ₂ /h
	1345	10759	kg O ₂ /h
	21375	171000	Nm ³ /h
	119,2	119,2	m
	14,0	14,0	m
	1669	13350	m ²
	1	8	piece
	18,9	18,9	%
	0,2	0,2	m ²
	315,0	2520,0	m ²
	no	no	
	yes	yes	
	≤ 30	≤ 30	mbar

The a.m technical data should be considered for the layout of the agitator acc. to VDMA 24656.

¹ Nm³ acc. to DIN EN ISO 1343 at t=0°C, p=1,01325bar, relative humidity = 0%

Project: waste water treatment plant Gabal el Asfar

sketch with a proposal of a possible arrangement


15 liftable grids each with 3 distribution pipes and 35 x OXYFLEX® MF1100 per distribution pipe

105 diffuser per grid

Σ 1575 OXYFLEX® MF1100 per tank

required air amount	:	7108 Nm ³ /h ¹
standard oxygen transfer rate (SOTR/SOR)	:	925 kg O ₂ / h
specific standard oxygen transfer rate (SSOTR)	:	21,5 g O ₂ /Nm ³ /m ¹ installation depth ¹
diffuser working depth	:	6,05 m

resulted air feed per diffusers	:	4,5 Nm ³ /h per diffuser ¹
resulted air feed per m ² of diffuser surface	:	22,6 Nm ³ /h per m ² active diffuser area ¹
floor area of the tank	:	1669 m ²
total active diffuser area	:	315 m ²
diffuser coverage density	:	18,9 %



¹ Nm³ acc. to DIN EN ISO 1343 at t=0°C, p=1,01325bar, relative humidity = 0%